



161100110161



中国认可
国际互认
检测
TESTING
CNAS L0116

国家强制性产品认证 试验报告

☐新申请 ☒变更 ☐监督 ☐复审 ☐其他:

申请编号: A2020CCC0307-3530321

产品名称: 万能式断路器

型 号: TeW5-3200、TeW5-3200/4
TeW5F-3200、TeW5F-3200/4
TeW5F-3200HU、TeW5F-3200HU/4
TeW5F-3200HUH、TeW5F-3200HUH/4

检测机构: 浙江方圆检测集团股份有限公司
(浙江方圆电气设备检测有限公司)



申请编号: A2020CCC0307-3530321 样品名称: 万能式断路器 型 号: TeW5-3200、TeW5-3200/4 TeW5F-3200、TeW5F-3200/4 TeW5F-3200HU、TeW5F-3200HU/4 TeW5F-3200HUH、TeW5F-3200HUH/4 数 量: 11 台 商 标:  样品来源: 生产企业送样 收样日期: 2020-07-15 完成日期: 2020-08-03	委 托 人: 浙江天正智能电器有限公司 委托人地址: 浙江省嘉兴市秀洲区中山西路 2777 号 生 产 者: 浙江天正智能电器有限公司 生产者地址: 浙江省嘉兴市秀洲区中山西路 2777 号 生 产 企 业: 浙江天正智能电器有限公司 生产企业地址: 浙江省嘉兴市秀洲区中山西路 2777 号
试验结论: 依据 GB/T 14048.2-2008 检验合格	
本申请认证单元所覆盖的产品型号规格及相关情况说明: TeW5-3200、TeW5-3200/4、TeW5F-3200、TeW5F-3200/4、TeW5F-3200HU、TeW5F-3200HU/4、 TeW5F-3200HUH、TeW5F-3200HUH/4; Ui: 1250V; Uimp: 12kV; In: 2000A, 2500A, 2900A, 3200A; TeW5-3200、TeW5-3200/4、TeW5F-3200、TeW5F-3200/4: Ue: AC380V/400V/415V、AC660V/690V; AC380V/400V/415V: Ics=100kA; Icu=100kA; Icw=100kA/1s, Icw=65kA/3s; AC660V/690V: Ics=85kA; Icu=85kA; Icw=85kA/1s, Icw=65kA/3s; TeW5F-3200HU、TeW5F-3200HU/4: Ue: AC800V/1000V/1140V; Ics=50kA; Icu=50kA; Icw=50kA/1s; TeW5F-3200HUH、TeW5F-3200HUH/4: Ue: AC800V、1000V/1140V; AC800V: Ics=75kA; Icu=75kA; Icw=75kA/1s; AC1000V/1140V: Ics=60kA; Icu=60kA; Icw=60kA/1s; 过电流脱扣器类型: 电子式; 使用类别: B 类; 适用频率: 50/60Hz; 极数: 3P, 4P; 产品适用于隔离; 符合附录 N 的电子附件: 欠压脱扣器 QTW45, Us: AC220V/230V/240V, AC380V/400V/415V; 分励脱扣器 FTW45, Us: AC220V/230V/240V, AC380V/400V/415V, DC110V, DC220V; 闭合线圈 BG45, Us: AC220V/230V/240V, AC380V/400V/415V, DC110V, DC220V; 配用的辅助触头 F-W1 (4NO4NC、6NO6NC、8NO8NC、10NO10NC): Ith: 10A; AC-15: Ue/Ie: AC400V/2A; DC-13: Ue/Ie: DC250V/0.3A;	
主检: 金宏飞 签名:  日期: 2020-08-07	
审核: 陆林林 签名:  日期: 2020-08-07	
签发: 王国忠 签名:  日期: 2020-08-07	
备注: 该申请为变更申请, 具体变更项目和原 3C 认证情况详见附页:	