

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Moulded Case Circuit-breakers

Name and address of the applicant

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province,
P.R.China

Name and address of the manufacturer

Zhejiang Tengen Electric Co.,Ltd.
Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province,
P.R.China

Name and address of the factory

Note: When more than one factory, please report on page 2

Zhejiang Tengen Electric Co.,Ltd.
No.288 Central Avenue, Development Zone, Yueqing City, Zhejiang
Province

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

Tache

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

TeM5ED-125L, TeM5ED-125M, TeM5ED-125H, TeM5ED-250L,
TeM5ED-250M, TeM5ED-250HAdditional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity with

IEC 60947-2:2016(5th Edition)

As shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2020CQC-093086

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE


Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Dec.09,2020

Signature:



Lu Mei

CB 0059471


TeM5ED-125L, TeM5ED-125M, TeM5ED-125H, TeM5ED-250L, TeM5ED-250M, TeM5ED-250H;
Uimp: 8kV;
Ui: 1000V;
Ue: AC380V/AC400V/AC415V;
In: 63-125A (adjustable) (TeM5ED-125L, TeM5ED-125M, TeM5ED-125H);
100-250A (adjustable) (TeM5ED-250L, TeM5ED-250M, TeM5ED-250H);
Over-current release: electronic;
Ics: 35kA(L), 50kA(M), 65kA(H);
Icu: 50kA(L, M), 85kA(H);
Selectivity category: A;
3P, 3P+N (3 protected poles with an uninterrupted neutral pole);
50Hz/60Hz;
Applicable for isolation (except for 3P+N);
IP20 (except for the terminals);
Auxiliary contact and alarm contact: OF-M, SD-M;
1NO1NC, 2NO2NC, 4NO4NC;
Ith: 3A;
AC-15: Ue/Ie: AC380V/AC400V/AC415V/0.3A;
DC-13: Ue/Ie: DC110V/DC220V/DC250V/0.15A

Page 1 of 1

Additional information (if necessary)

Date: Dec.09,2020

Signature:



Lu Mei