



Ref. Certif. No.

CN43731

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

Product
Produit

Air Circuit-breaker

Name and address of the applicant
Nom et adresse du demandeur

Zhejiang Tengen Smart Electrics Co.,Ltd.
No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing,
Zhejiang Province, P.R.China

Name and address of the manufacturer
Nom et adresse du fabricant

Zhejiang Tengen Smart Electrics Co.,Ltd.
No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing,
Zhejiang Province, P.R.China

Name and address of the factory
Nome et adresse de l'usine

Zhejiang Tengen Smart Electrics Co.,Ltd.
No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing,
Zhejiang Province, P.R.China

Note: When more than one factory, please report on page 2
Note: Lorsqu'il y a plus d'une usine, veuillez utiliser la 2^{ème} page

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

see the appendix

Trademark (if any)
Marque de fabrique (si elle existe)

/

Model / Type Ref.
Ref. De type

TeW5-1600、TeW5-1600/4

Additional information (if necessary may also be reported
on page 2)
Les informations complémentaires (si nécessaire, peuvent être
indiqués sur la 2^{ème} page)

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

PUBLICATION **EDITION**
IEC 60947-2:2006(4th Edition) + AMD 1:2009 + AMD 2:2013

As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

00901-CB2017CQC-078006

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de Certification



CHINA QUALITY CERTIFICATION CENTRE

Date: Jun.21,2018

Signature:

Wang Kejiao

Issued 2003-05
China Quality Certification Centre
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86-10-83886666
Fax: +86-10-83886282

website
www.cqc.com.cn

CB 0044489

TeW5-1600,TeW5-1600/4;
Ui: 1000V;
Uimp: 12kV;
Ue: AC380/400/415V,AC660/690V;
In:200A,400A,630A,800A,1000A,1250A,1600A;
Electronic
Ics:AC380/400/415V:55kA ,AC660/690V:42kA;
Icu:AC380/400/415V:65kA ,AC660/690V:50kA;
Iew:AC380/400/415V:55kA/1s,30kA/3s;
AC660/690V:42kA/1s,30kA/3s;
Selectivity category: B;
50/60Hz;
IP40;
Suitablefor insulation
3P, 4P;
Auxiliary contactF-W2 (4NO4NC, 5NO5NC, 6NO6NC):
Ui:400V;
Ith: 6A;
AC-15: Ue/Ie: AC400V/0.9A,AC230V/1.5A;
DC-13: Ue/Ie: DC220V/0.27A,DC110V/0.55A;
Accessories with electronic circuits:
Undervoltage release: QTW45,Us:AC220/230/240V,AC380/400/415V;
Shunt release: FTW45,Us: AC380/400/415V,AC220/230/240V,DC220V,DC110V;

Page 1 of 1

Additional information (if necessary)

Information complémentaire (si nécessaire)

Date: Jun.21,2018

Signature:



Wang Kejiao