



Ref. Certif. No.

CN43725

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST  
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)  
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE  
CERTIFICATS D'ESSAIS DES EQUIPEMENTS  
ELECTRIQUES (IECEE) METHODE OC

## CB TEST CERTIFICATE

Product  
Produit

Air Circuit-breaker

Name and address of the applicant  
Nom et adresse du demandeur

Zhejiang Tengen Smart Electrics Co.,Ltd.  
No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing,  
Zhejiang Province, P.R.China

Name and address of the manufacturer  
Nom et adresse du fabricant

Zhejiang Tengen Smart Electrics Co.,Ltd.  
No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing,  
Zhejiang Province, P.R.China

Name and address of the factory  
Nome et adresse de l'usine

Zhejiang Tengen Smart Electrics Co.,Ltd.  
No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing,  
Zhejiang Province, P.R.China

Note: When more than one factory, please report on page 2  
Note: Lorsqu'il y a plus d'une usine, veuillez utiliser la 2<sup>ème</sup> page

Ratings and principal characteristics  
Valeurs nominales et caractéristiques principales

see the appendix

Trademark (if any)  
Marque de fabrique (si elle existe)

/

Model / Type Ref.  
Ref. De type

TeW5-2000、TeW5-2000/4

Additional information (if necessary may also be reported  
on page 2)  
Les informations complémentaires (si nécessaire, peuvent être  
indiqués sur la 2<sup>ème</sup> page)

PUBLICATION

EDITION

A sample of the product was tested and found  
to be in conformity with  
Un échantillon de ce produit a été essayé et a été  
considéré conforme à la

IEC 60947-2:2006(4th Edition) + AMD 1:2009 + AMD 2:2013

As shown in the Test Report Ref. No. which forms part  
of this Certificate  
Comme indiqué dans le Rapport d'essais numéro de  
référence qui constitue partie de ce Certificat

00901-CB2017CQC-078008

This CB Test Certificate is issued by the National Certification Body  
Ce Certificat d'essai OC est établi par l'Organisme National de Certification



CHINA QUALITY CERTIFICATION CENTRE

Date: Jun.21,2018

Signature:

Wang Kejiao

TeW5-2000,TeW5-2000/4;  
Ui: 1000V;  
Uimp: 12kV;  
Ue: AC380/400/415V,AC660/690V;  
In: 400A,630A,800A, 1000A, 1250A, 1600A,1900A, 2000A ;  
Electronic  
Ics: AC380/400/415V:85kA AC660/690V:65kA;  
Icu: AC380/400/415V:85kA AC660/690V:65kA;  
Icw:AC380/400/415V:85kA/1s,50kA/3s;  
AC660/690V:65kA/1s,50kA/3s ;  
Selectivity category: B;  
50/60Hz;  
IP40;  
Suitablefor insulation  
3P, 4P;  
Auxiliary contactF-W1(4NO4NC,6NO6NC, 8NO8NC,10NO10NC):  
Ui:400V;  
Ith: 10A;  
AC-15: AC400V/2A;  
DC-13: DC250V/0.3A ;  
Accessories with electronic circuits:  
Undervoltage release: QTW45,Us:AC220/230/240V,AC380/400/415V;  
Shunt release: FTW45,Us: AC380/400/415V,AC220/230/240V,DC220V,DC110V ;  
Closing coil: BG45,Us: AC380/400/415V,AC220/230/240V,DC220V,DC110V

Page 1 of 1

Additional information (if necessary)

Information complémentaire (si nécessaire)

Date: Jun.21,2018

Signature:   
Wang Kejiao