



Ref. Certif. No.

CN43843

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC**CB TEST CERTIFICATE**Product
Produit

Air Circuit-breaker

Name and address of the applicant
Nom et adresse du demandeurZhejiang Tengen Smart Electrics Co.,Ltd.
No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing,
Zhejiang Province, P.R.ChinaName and address of the manufacturer
Nom et adresse du fabricantZhejiang Tengen Smart Electrics Co.,Ltd.
No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing,
Zhejiang Province, P.R.ChinaName and address of the factory
Nome et adresse de l'usineZhejiang Tengen Smart Electrics Co.,Ltd.
No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing,
Zhejiang Province, P.R.ChinaNote: When more than one factory, please report on page 2
Note: Lorsqu'il y a plus d'une usine, veuillez utiliser la 2^{ème} pageRatings and principal characteristics
Valeurs nominales et caractéristiques principales

see the appendix

Trademark (if any)
Marque de fabrique (si elle existe)

/

Model / Type Ref.
Ref. De type

TeW5-2500、TeW5-2500/4

Additional information (if necessary may also be reported
on page 2)
Les informations complémentaires (si nécessaire, peuvent être
indiqués sur la 2^{ème} page)A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à laAs shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat**PUBLICATION****EDITION**

IEC 60947-2:2006(4th Edition) + AMD 1:2009 + AMD 2:2013

00901-CB2017CQC-078007

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification****CHINA QUALITY CERTIFICATION CENTRE**

Date: Jul.02,2018

Signature: Wang Kejiao

Issued 2003-05
China Quality Certification Centre
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.ChinaTel: +86-10-83886666
Fax: +86-10-83886282website
www.cqc.com.cn**CB 0044013**

TeW5-2500,TeW5-2500/4
Ui: 1000V;
Uimp: 12kV;
Ue: AC380/400/415V,AC660/690V;
In:630A,800A,1000A,1250A,1600A,1900A,2000A,2500A;
Electronic
Ics:AC380/400/415V:85kA ,AC660/690V:75kA;
Icu:AC380/400/415V:85kA ,AC660/690V:75kA;
Icw:AC380/400/415V:85kA/1s,50kA/3s;
AC660/690V:75kA/1s,50kA/3s;
Selectivity category: B
50/60Hz;
IP40;
Suitablefor insulation
3P, 4P;
Auxiliary contactF-W1(4NO4NC,6NO6NC, 8NO8NC,10NO10NC):
Ui:400V;
Ith: 10A;
AC-15: AC400V/2A;
DC-13: DC250V/0.3A ;
Accessorieswith electronic circuits:
Undervoltage release: QTW45,Us:AC220/230/240V,AC380/400/415V;
Shunt release: FTW45,Us: AC380/400/415V,AC220/230/240V,DC220V,DC110V;
Closing coil: BG45,Us: AC380/400/415V,AC220/230/240V,DC220V,DC110V

Page 1 of 1

Additional information (if necessary)

Information complémentaire (si nécessaire)

Date: Jul.02,2018

Signature:



Wang Kejiao