



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE180303005808

Product

Miniature circuit breaker

Applicant

Zhejiang Tengen Smart Electrics Co.,Ltd.

No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing,
Zhejiang Province, P.R.China

Type/Model

TeB5-63,TeB5-63H

Technical data

Ui:690V;Uimp:4kV;Ue: AC230V/400V(1P),
AC400V(2P,3P,4P);In:1A,2A,3A,4A,5A,6A,10A,16A,20A,2
5A,32A,40A,50A,63A;Type of instantaneous tripping
current: B,C,D;TeB5-63:Ics=Icn:6kA;TeB5-63H: Ics: 7.5kA,
Icn:10kA;Poles: 1P,2P,3P,4P

This is to certify that, on the basis of the tests undertaken as per Report No.
03601-A-18D0006-S, the submitted sample(s) of the above item complies with:

EN 60898-1:2003 + A11:2005

and fulfills testing requirements of the European Directive:

2014/35/EU

Valid from: May.17,2018

Valid until: May.17,2021

President:



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>