



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE200303007073

Product

Moulded Case Circuit-breakers

Applicant

Zhejiang Tengen Smart Electrics Co.,Ltd.

No.2777 West Zhongshan Road, Xiuzhou District, Jiaxing,
Zhejiang Province, P.R.China

Type/Model

TeM7E-400L, TeM7E-400M, TeM7E-400H, TeM7E-400S,
TeM7E-400R, TeM7E-630L, TeM7E-630M,
TeM7E-630H, TeM7E-630S, TeM7E-630R

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No.
00901-CE2020CQC0303-011321, the submitted sample(s) of the above item complies
with:

EN60947-2:2017

and fulfills testing requirements of the European Directive:

Low Voltage Directive (LVD): 2014/35/EU

Valid from: Dec.30,2020

Valid until: Dec.30,2023

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

CE 0010643



CHINA QUALITY CERTIFICATION CENTRE

CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 2

Certificate No.: CE200303007073

TeM7E-400L, TeM7E-400M, TeM7E-400H, TeM7E-400S, TeM7E-400R,
TeM7E-630L, TeM7E-630M, TeM7E-630H, TeM7E-630S, TeM7E-630R;

Uimp:12kV;

Ui:1000V;

Ue:AC380V/AC400V/AC415V, AC500V/AC550V, AC660V/AC690V;

In:

160A, 180A, 200A, 225A, 250A, 280A, 315A, 350A, 375A, 400A (adjustable) (TeM7E-400);
250A, 280A, 315A, 350A, 375A, 400A, 450A, 500A, 560A, 630A (adjustable) (TeM7E-630);

Over-current release: electronic;

Ics:

AC380V/AC400V/AC415V: 50kA(L), 85kA(M), 100kA(H), 150kA(S), 200kA(R);

AC500V/AC550V: 50kA(L, M), 70 kA (H, S), 85kA(R);

AC660V/AC690V: 20kA(L, M), 40kA(H, S), 80kA(R);

Icu:

AC380V/AC400V/AC415V: 50kA(L), 85kA(M), 100kA(H), 150kA(S), 200kA(R);

AC500V/AC550V: 50kA(L, M), 70 kA (H, S), 85kA(R);

AC660V/AC690V: 20kA(L, M), 40kA(H, S), 80kA(R);

Selectivity category: B;

3P, 3P+N(3 protected poles with an uninterrupted neutral pole), 4P;

50Hz/60Hz;

Applicable for isolation(except for 3P+N);

IP20 (except for the terminals);

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Appendix

Page 2 of 2

Certificate No.: CE200303007073

Auxiliary contact and alarm contact:

1NO1NC,2NO2NC,3NO3NC,4NO4NC;

Ith: 3A;

AC-15:Ue/Ie:AC400V/1.5A;

DC-13:Ue/Ie:DC220V/0.15A;

Accessories complied with Annex N:

Electric operator: Us:DC24V,DC110V,DC220V,AC110V,AC230V,AC400V,50/60Hz

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>